

limited to, any records required by 40 CFR part 75.

(3) Records of all major maintenance activities conducted on emission units, air pollution control equipment, and CEMS.

(4) Any other records required by 40 CFR part 75.

(g) *Reporting.* All reports under this section shall be submitted to the Director, Office of Enforcement, Compliance and Environmental Justice, U.S. Environmental Protection Agency, Region 8, Mail Code 8ENF-AT, 1595 Wynkoop Street, Denver, Colorado 80202-1129.

(1) Owner/operator shall submit quarterly excess emissions reports no later than the 30th day following the end of each calendar quarter. Excess emissions means emissions that exceed the emissions limits specified in paragraph (c) of this section. The reports shall include the magnitude, date(s), and duration of each period of excess emissions, specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the unit, the nature and cause of any malfunction (if known), and the corrective action taken or preventative measures adopted.

(2) Owner/operator shall submit quarterly CEMS performance reports, to include dates and duration of each period during which the CEMS was inoperative (except for zero and span adjustments and calibration checks), reason(s) why the CEMS was inoperative and steps taken to prevent recurrence, any CEMS repairs or adjustments, and results of any CEMS performance tests required by 40 CFR part 75 (Relative Accuracy Test Audits, Relative Accuracy Audits, and Cylinder Gas Audits).

(3) When no excess emissions have occurred or the CEMS has not been inoperative, repaired, or adjusted during the reporting period, such information shall be stated in the report.

(h) *Notifications.* (1) Owner/operator shall submit notification of commencement of construction of any equipment which is being constructed to comply with the NO_x emission limits in paragraph (c) of this section.

(2) Owner/operator shall submit semi-annual progress reports on construction of any such equipment.

(3) Owner/operator shall submit notification of initial startup of any such equipment.

(i) *Equipment operation.* At all times, owner/operator shall maintain each unit, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

(j) *Credible Evidence.* Nothing in this section shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with requirements of this section if the appropriate performance or compliance test procedures or method had been performed.

[77 FR 20944, Apr. 6, 2012]

§§ 52.1826–52.1828 [Reserved]

§ 52.1829 Prevention of significant deterioration of air quality.

(a) The North Dakota plan, as submitted, is approved as meeting the requirements of Part C, Title I, of the Clean Air Act, except that it does not apply to sources proposing to construct on Indian Reservations.

(b) Regulation for preventing of significant deterioration of air quality. The provisions of § 52.21 except paragraph (a)(1) are hereby incorporated and made a part of the North Dakota State implementation plan and are applicable to proposed major stationary sources or major modifications to be located on Indian Reservations.

[44 FR 63103, Nov. 2, 1979. Correctly designated at 44 FR 75635, Dec. 21, 1979, as amended at 68 FR 11324, Mar. 10, 2003; 68 FR 74490, Dec. 24, 2003]

§ 52.1831 Visibility protection.

A revision to the SIP was submitted by the Governor on April 18, 1989, for visibility general plan requirements and long-term strategies.

[54 FR 41098, Oct. 5, 1989]

§ 52.1832 Stack height regulations.

The State of North Dakota has committed to revise its stack height regulations should EPA complete rule-making to respond to the decision in *NRDC v. Thomas*, 838 F. 2d 1224 (D.C. Cir. 1988). In a letter to Douglas M.